

TWIN CITY TESTING AND ENGINEERING LABORATORY, INC.

ENGINEERS AND CHEMISTS

662 Cromwell Avenue - St. Paul, Minn. 55114

REPORT OF QUANTITATIVE CHEMICAL EXAMINATION

SAMPLE: WATER
REPORTED TO: Reilly Tar & Chemical Company
 7200 Walker Street
 St. Louis Park, Minnesota 55426
 Attention: Mr. P. E. White

DATE: May 9, 1968

US EPA RECORDS CENTER REGION 5



514886

Laboratory No. 2-8242**Sample Identification:**

- (a) Effluent water
- (b) Tar separator

Results:

<u>CONSTITUENT</u>	(a) <u>P.P.M.</u>	(b) <u>P.P.M.</u>
Phenol	20	16
Oil	207	88

Remarks: The samples were received for analysis April 29, 1968.

302474

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

ALL REPORTS WILL BE HELD TWO (2) MONTHS FROM DATE RECEIVED, THEN DESTROYED, UNLESS WRITTEN INSTRUCTIONS TO THE CONTRARY ARE SUBMITTED BY THE CLIENT.

Twin City Testing and Engineering Laboratory, Inc.

By R. J. Stever